


**CWIEME**  
BERLIN

14-16 MAY 2024  
MESSE BERLIN



# The impact of a potential tighter energy performance regulation for power distribution transformers



International Copper  
Association Europe



[berlin.cwiemeevents.com](http://berlin.cwiemeevents.com)



# **Agenda**

**Ecodesign regulation for power transformers under revision**

**Potential introduction of Tier 3 energy performance requirements**

**What will be the impact on:**

- **Energy savings**
- **Material use**
- **Impact on volume**
- **Investment and life cycle cost**
- **Life Cycle Assessment**

**Conclusions and recommendations**



# Ecodesign regulation

## Requirements for three-phase medium power transformers with rated power $\leq 3\,150$ kVA

Rated Power (kVA)	Tier 1 (from 1 July 2015)	
	Maximum load losses $P_k$ (W) (*)	Maximum no-load losses $P_o$ (W) (*)
$\leq 25$	$C_k$ (900)	$A_o$ (70)
50	$C_k$ (1 100)	$A_o$ (90)
250	$C_k$ (3 250)	$A_o$ (300)
315	$C_k$ (3 900)	$A_o$ (360)
400	$C_k$ (4 600)	$A_o$ (430)
500	$C_k$ (5 500)	$A_o$ (510)
630	$C_k$ (6 500)	$A_o$ (600)
2 000	$B_k$ (18 000)	$A_o$ (1 450)
2 500	$B_k$ (22 000)	$A_o$ (1 750)
3 150	$B_k$ (27 500)	$A_o$ (2 200)

Tier 2 (from 1 July 2021)	
Maximum load losses $P_k$ (W) (*)	Maximum no-load losses $P_o$ (W) (*)
$A_k$ (600)	$A_o - 10\%$ (63)
$A_k$ (750)	$A_o - 10\%$ (81)
$A_k$ (2 350)	$A_o - 10\%$ (270)
$A_k$ (2 800)	$A_o - 10\%$ (324)
$A_k$ (3 250)	$A_o - 10\%$ (387)
$A_k$ (3 900)	$A_o - 10\%$ (459)
$A_k$ (4 600)	$A_o - 10\%$ (540)
$A_k$ (15 000)	$A_o - 10\%$ (1 305)
$A_k$ (18 500)	$A_o - 10\%$ (1 575)
$A_k$ (23 000)	$A_o - 10\%$ (1 980)

# Ecodesign regulation

## Requirements for three-phase medium power transformers with rated power $\leq 3\,150$ kVA

Rated Power (kVA)	Tier 1 (from 1 July 2015)	
	Maximum load losses $P_k$ (W) (*)	Maximum no-load losses $P_o$ (W) (*)
$\leq 25$	$C_k$ (900)	$A_o$ (70)
50	$C_k$ (1 100)	$A_o$ (90)
250	$C_k$ (3 250)	$A_o$ (300)
315	$C_k$ (3 900)	$A_o$ (360)
400	$C_k$ (4 600)	$A_o$ (430)
500	$C_k$ (5 500)	$A_o$ (510)
630	$C_k$ (6 500)	$A_o$ (600)
2 000	$B_k$ (18 000)	$A_o$ (1 450)
2 500	$B_k$ (22 000)	$A_o$ (1 750)
3 150	$B_k$ (27 500)	$A_o$ (2 200)

Tier 2 (from 1 July 2021)	
Maximum load losses $P_k$ (W) (*)	Maximum no-load losses $P_o$ (W) (*)
$A_k$ (600)	$A_o - 10\%$ (63)
$A_k$ (750)	$A_o - 10\%$ (81)
$A_k$ (2 350)	$A_o - 10\%$ (270)
$A_k$ (2 800)	$A_o - 10\%$ (324)
$A_k$ (3 250)	$A_o - 10\%$ (387)
$A_k$ (3 900)	$A_o - 10\%$ (459)
$A_k$ (4 600)	$A_o - 10\%$ (540)
$A_k$ (15 000)	$A_o - 10\%$ (1 305)
$A_k$ (18 500)	$A_o - 10\%$ (1 575)
$A_k$ (23 000)	$A_o - 10\%$ (1 980)

Would TIER 3 make sense?

# Modelling exercise for a 630 kVA unit




Rated power	630 kVA
Rated frequency	50 Hz
Number of phases	3
Short circuit impedance	4%
MV winding $U_m$	$U_m \leq 24$ kV
LV winding $U_m$	$U_m \leq 1.1$ kV
Type	liquid-immersed

Material	Cost per kg
Aluminium	€6.00
Copper	€12.00
Magnetic sheet (quality M070 = 0.70 W/kg at 1.7 T)	€5.50
Oil	€2.00
Tank + cover	€4.50

Other parameters	
Root Mean Square load	20% to 40% (30% base case)
Lifetime	40 years
Electricity price	0.10 to 0.16 €/kWh (0.13 base case)
Annual interest rate	2%

# Modelling exercise for a 630 kVA unit

		Load losses		
		Ak	Ak-5%	Ak-10%
No-load losses	A0-10%	Tier 2		
	A0-15%		<u>Tier 3a</u>	
	A0-20%			<u>Tier 3b</u>



Al

Al

Al

Cu

Cu

Cu

## Two options


Aluminium windings

Copper windings




# Energy savings potential

Energy savings compared to Tier 2  
(kWh/year) – Transformer 630 kVA




In the EU-27, potential electricity savings of Tier 3b are estimated at **1.8 TWh/year**.



With a 40-year average distribution transformer capacity in EU-27 of 1,250 GVA.

# Why each kWh saved matters?



2030: -55%

2040: -90%

2050: carbon neutral

2030 final energy consumption is **CAPPED to 763 Mtoe**


For reference, final energy consumption was **940 Mtoe in 2022**

→ Needs a reduction equivalent to the whole consumption of Germany, to be implemented in just 8 years



# Why each kWh saved matters?


By 2050 the situation is to get even tougher,  
with final energy consumption further capped to **~600 Mtoe**




Source: Impact Assessment EU Green Deal – Part 2, Figure 37

<https://eur-lex.europa.eu/legal-content/EN/TXT/DOC/?uri=CELEX:52020SC0176>

# Materials use



The increased material use for transformer manufacturing is compensated by a lower need for power generation assets (thanks to lower energy losses)




# Transformer: bill of materials

Al/Al windings	Tier 2 A <sub>0</sub> -10% A <sub>k</sub>	Tier 3a A <sub>0</sub> -15% A <sub>k</sub> -5%	Tier 3b A <sub>0</sub> -20% A <sub>k</sub> -10%
Aluminium (kg)	426	489	465
Magnetic steel (kg)	1106	1280	1370
Oil (kg)	366	387	435
Tank + cover (kg)	298	285	345
Mass of metals (kg)	2,004	2,203	2,295
<b>Total mass (kg)</b>	<b>2,370</b>	<b>2,590</b>	<b>2,730</b>

Cu/Cu windings	Tier 2 A <sub>0</sub> -10% A <sub>k</sub>	Tier 3a A <sub>0</sub> -15% A <sub>k</sub> -5%	Tier 3b A <sub>0</sub> -20% A <sub>k</sub> -10%
Copper (kg)	631	698	735
Magnetic steel (kg)	633	746	1020
Oil (kg)	262	280	300
Tank + cover (kg)	264	251	270
Mass of metals (kg)	1,679	1,851	2,125
<b>Total mass (kg)</b>	<b>1,941</b>	<b>2,131</b>	<b>2,425</b>

Bill of materials as per International Copper Association Europe modelling exercise




# Transformer: bill of materials

Al/Al windings	Tier 2 A <sub>0</sub> -10% A <sub>k</sub>	Tier 3a A <sub>0</sub> -15% A <sub>k</sub> -5%	Tier 3b A <sub>0</sub> -20% A <sub>k</sub> -10%
Aluminium (kg)	100%	115%	109%
Magnetic steel (kg)	100%	116%	124%
Oil (kg)	100%	106%	119%
Tank + cover (kg)	100%	96%	116%
Mass of metals (kg)	100%	110%	115%
Total mass (kg)	100%	109%	115%

Cu/Cu windings	Tier 2 A <sub>0</sub> -10% A <sub>k</sub>	Tier 3a A <sub>0</sub> -15% A <sub>k</sub> -5%	Tier 3b A <sub>0</sub> -20% A <sub>k</sub> -10%
Copper (kg)	100%	111%	116%
Magnetic steel (kg)	100%	118%	161%
Oil (kg)	100%	107%	115%
Tank + cover (kg)	100%	95%	102%
Mass of metals (kg)	100%	110%	127%
Total mass (kg)	100%	110%	125%

Bill of materials as per International Copper Association Europe modelling exercise




## Onshore wind: bill of materials

Material	Kg / kW onshore wind
Steel	143
Cast iron	12
Composites and polymers	29
Other metals and alloys	19
Concrete	404
Road aggregate	613
Other materials	3
<b>Total</b>	<b>1,223</b>

The U.S. Department of Energy (DOE) Renewable Energy Materials Properties Database (REMPD). Available online: <https://www.nrel.gov/wind/materials-database.html> (accessed on 2 April 2024).

# EU Electricity generation mix as modelled in the EU Green Deal



**New capacity is fully dominated by wind (onshore and offshore) and solar**

Electricity mix as modelled in the Green Deal impact assessment

[https://climate.ec.europa.eu/document/download/ec1acac9-10fe-4eeb-915f-cad388990e0f\\_en?filename=2030 climate target plan figures en.xlsx](https://climate.ec.europa.eu/document/download/ec1acac9-10fe-4eeb-915f-cad388990e0f_en?filename=2030%20climate%20target%20plan%20figures%20en.xlsx)

# How much material is saved when we spare 1 kWh?




## Renewable Energy Materials Properties Database: Summary


Aubryn Cooperman, Annika Eberle, Dylan Hettinger, Melinda Marquis, Brittany Smith, Richard F. Tusing, and Julien Walzberg

National Renewable Energy Laboratory

Entire Land-Based Wind Power Plant  
(Total Material Intensity  
~1,200,000 kg/MW)



Entire Offshore Wind Power Plant  
(Total Material Intensity  
~290,000 kg/MW)



Wind Turbine Only  
(Total Material Intensity  
~130,000 kg/MW)





Figure 3. Typical high-level breakdown of wind energy materials by mass as reported in the REMPD

# How much material is saved when we spare 1 kWh?


**1 kWh/year of electricity losses avoided saves 0.75 kg of materials, of which 0.15 kg of metals**

Material Category	Onshore wind (kg/kWh)	Offshore wind (kg/kWh)	PV (kg/kWh)	EU marginal mix* (kg/kWh)
Concrete	0,389	0,000	0,032	<b>0,227</b>
Road aggregate	0,590	0,000	0,000	<b>0,331</b>
Steel	0,138	0,137	0,048	<b>0,112</b>
Composites and polymers	0,028	0,009	0,015	<b>0,021</b>
Cast iron	0,012	0,005	0,016	<b>0,012</b>
Other metals and alloys	0,018	0,011	0,035	<b>0,022</b>
Other materials	0,003	0,001	0,090	<b>0,027</b>
<b>TOTAL</b>	<b>1,178</b>	<b>0,164</b>	<b>0,236</b>	<b>0,752</b>

\* Marginal electricity generation capacity additions based on the EU Green Deal Impact Assessment: 56% onshore wind, 15% offshore wind, 28% solar




# Metals used in transformer



- **More stringent MEPS result in a higher amount of metals used in the transformer.**
- **A design with copper windings is lighter than one with aluminium windings.**

*% relative to a Tier 2 unit with aluminium windings*


# Metals used in system: transformer + electricity generation



- Metal use increases only slightly for combination of transformer AND associated generation assets.
- A design with copper windings is lighter than one with aluminium windings.

*% relative to a Tier 2 unit with aluminium windings*


# Material use: **all materials** combined



- The weight of all materials needed in the transformer and in the generation assets compensating for transformer losses (including concrete, road aggregate, etc.) reduces with higher energy performance.
- A design with copper windings saves more material compared to its aluminium counterpart.

*% relative to a Tier 2 unit with aluminium windings*

# Interior volume




- The higher the energy performance, the bigger the transformer volume.
- In space-constrained applications, the use of copper windings allows for reducing the volume compared to its aluminium counterpart, while increasing the energy performance

*% relative to a Tier 2 unit with aluminium windings*

# Economic impact

**The bigger investment cost of a Tier 3 unit is compensated by a lower cost of losses, resulting in a TCO similar to that of a Tier 2 unit.**


A design with copper windings ends up slightly more expensive than one with aluminium windings but comes with benefits in terms of volume, weight and embedded CO<sub>2eq</sub> emissions.



% relative to Tier 2

# Economic impact: sensitivity to electricity price

Average price of electricity for final consumers (inflation corrected, €2015) ranges between **16c€/kWh** in 2030 and **22 c€/kWh** in 2050.



Source: Impact Assessment EU Green Deal – Part 2, Figure 87

<https://eur-lex.europa.eu/legal-content/EN/TXT/DOC/?uri=CELEX:52020SC0176>

# Economic impact: sensitivity to electricity price

The conclusions remain similar with different electricity prices, but:


- the TCO slightly increases (3%) at the lowest electricity price
- the **TCO slightly decreases** (up to -4%) at the highest electricity price, which is the **most likely scenario**



# Economic impact: sensitivity to transformer loading

The conclusions remain similar with different transformer loadings, but

- the TCO slightly increases (<3%) at the lowest load profile
- the **TCO slightly decreases** (up to -4%) at the highest load profile, which is the **most likely scenario**




RMS: Root Mean Square of load




# Life cycle: manufacturing phase only

Cu Tier2 = 100%  
Manufacturing phase only



- The higher material use of Tier 3b translates into a 30% to 40% higher impact for the manufacturing phase.
- Units with aluminium windings use more material than their copper counterparts, which translates into a higher *Climate Change, Energy Use, Acidification and Photochemical Ozone*.

# LCA impact of future electricity mix



Electricity mix as modelled in the Green Deal impact assessment


[https://climate.ec.europa.eu/document/download/ec1acac9-10fe-4eeb-915f-cad388990e0f\\_en?filename=2030\\_climate\\_target\\_plan\\_figures\\_en.xlsx](https://climate.ec.europa.eu/document/download/ec1acac9-10fe-4eeb-915f-cad388990e0f_en?filename=2030_climate_target_plan_figures_en.xlsx)

Impact for 1 kWh electricity produced with		CLIMATE CHANGE TOTAL	FRESHWATER AND TERRESTRIAL ACIDIFICATION	ETC....
		[kg CO <sub>2</sub> -Eq]	[mol H <sup>+</sup> -Eq]	
Hard coal	PC, without CCS	1,02E+00	1,73E-03	
Hard coal	IGCC, without CCS	8,49E-01	1,05E-03	
Natural gas	NGCC, without CCS	4,34E-01	3,26E-04	
Hard coal	PC, with CCS	3,69E-01	1,80E-03	
Hard coal	IGCC, with CCS	2,79E-01	1,35E-03	
Natural gas	NGCC, with CCS	1,28E-01	6,07E-04	
Hydro	660 MW	1,47E-01	4,15E-04	
Hydro	360 MW	1,07E-02	4,45E-05	
Nuclear	average	5,29E-03	4,28E-05	
CSP	tower	2,17E-02	9,24E-05	
CSP	trough	4,20E-02	1,51E-04	
PV	poly-Si, ground-mounted	3,67E-02	3,01E-04	
PV	CdTe, roof-mounted	1,46E-02	8,82E-05	
PV	CIGS, ground-mounted	1,14E-02	6,11E-05	
PV	CIGS, roof-mounted	1,41E-02	8,64E-05	
Wind	onshore	1,24E-02	5,28E-05	
Wind	offshore, concrete foundation	1,42E-02	1,00E-04	
Wind	offshore, steel foundation	1,33E-02	9,45E-05	

UNECE: Integrated Life-cycle Assessment of Electricity Sources


<https://unece.org/documents/2022/08/integrated-life-cycle-assessment-electricity-sources>

# Life cycle: manufacturing and use phase



- Thanks to the energy savings, **most categories show a lower impact for Tier 3b than for Tier 2.**
- Copper designs offer better performance in categories that are key for the Green Deal: **Climate Change and Energy use. Also on Acidification and Photochemical Ozone.**

# Life cycle: manufacturing, use phase and recycling credits



- **Recycling credits significantly reduce the impact in many LCA categories.**
- **Recycling should therefore be further stimulated.**


# In a nutshell




**EU-27 savings potential of Tier 3 in power distribution transformers is about 1.8 TWh/year**



**Total cost of ownership of Tier 3 is similar or lower than Tier 2.**



**Tier 3 leads to bigger transformers, but the additional material use is moderated by a reduced need for generation, transmission and distribution assets.**




**When aluminium designs get too bulky / heavy in their Tier 3 versions, a good alternative is to shift to copper, which has a significantly smaller footprint and weight, while their total cost of ownership remains comparable to that of their aluminium counterpart.**




**Most LCA impact categories improve with Tier 3. The *Climate Change* and *Energy Use* impact categories improve even more when aluminium windings are replaced by copper.**



# Recommendations for the Ecodesign regulation



**Strengthen Minimum Energy Performance Standards (MEPS), as the 2030 energy saving targets require the use of every single opportunity that makes economic sense.**



**Introduce material efficiency requirements (MMPS), taking into account that an improved energy performance reduces the need for generation, transmission, and distribution assets.**



**Introduce Design-for-Recycling requirements. Ensure re-utilization of raw materials with minimum downcycling.**

# Thank you!

[fernando.nuno@internationalcopper.org](mailto:fernando.nuno@internationalcopper.org)

[bruno.dewachter@internationalcopper.org](mailto:bruno.dewachter@internationalcopper.org)

[angelo.baggini@unibg.it](mailto:angelo.baggini@unibg.it)

